



FORM U-1 (back)

18. INSPECTION Manholes, No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_  
 OPENINGS: Handholes, No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_  
 Threaded, No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_  
 19. SUPPORTS: Skirt \_\_\_\_\_ Lugs \_\_\_\_\_ Legs \_\_\_\_\_ Other straps (2) Attached welded  
 (Yes or No) (Number) (Number) (Describe) (Where & How)  
 on center line of vessel.

20. REMARKS:  
Date for T-575 gallon gross vacuum jacketed cryogenic storage vessel @ 250  
psig SA-240 T-304 stn. stl. non-corrosive service, inner vessel only. Outer  
vessel not code stamped.  
2, plus full external vacuum & hydro head.

(Brief description of purpose of the vessel, as Air Tank, After Cooler, Jacketed Cooker, etc. State contents of each part.)

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division I.

Date 1/18 19 72 Signed Ryan Industries, Inc. By [Signature]  
 (Manufacturer) Quality Control  
 Certificate of Authorization Expires December 31, 1972

CERTIFICATE OF SHOP INSPECTION

VESSEL MADE BY Ryan Industries at 4800 Allmond Ave., Louisville

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province Kentucky and employed by Employers Comm. Union Ins., Co of America

have inspected the pressure vessel described in this manufacturer's data report on Jan. 18, 19 72, and state that to the best of my knowledge and belief, the manufacturer has constructed this pressure vessel in accordance with the applicable sections of the ASME Boiler and Pressure Vessel Code.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date Jan. 18, 19 72 [Signature] Commissions Ohio 1367  
Pa. 1676  
N.B. 3364  
 Inspector's Signature Nat'l Board, State, or Province and No.

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province \_\_\_\_\_ and employed by \_\_\_\_\_ of \_\_\_\_\_

have compared the statements in this manufacturer's data report with the described pressure vessel and state that parts referred to as data items \_\_\_\_\_, not included in the certificate of shop inspection have been inspected by me and that to the best of my knowledge and belief the manufacturer has constructed and assembled this pressure vessel in accordance with the applicable sections of the ASME

Boiler and Pressure Vessel Code. The described vessel was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this manufacturer's data report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date \_\_\_\_\_ 19 \_\_\_\_\_  
 Inspector's Signature Commissions \_\_\_\_\_  
 Nat'l Board, State, or Province and No.