

**FORM U-1 MANUFACTURERS' DATA REPORT FOR UNFIRED PRESSURE VESSELS**  
As required by the Provisions of the ASME Code Rules

NB

1. Manufactured by Ryan Industries, Inc. Cleveland, Ohio  
(Name and address of Manufacturer)  
2. Manufactured for National Cylinder Gas Co. Chicago, Illinois  
(Name and address of Purchaser)  
3. Type Vertical Kind Jacketed Vessel No. 741 (Mfrs. Serial) (State & State No.)  
Natl. Id. No. 741 Yr. Built 1961

Items 4-9 incl. to be completed for single wall vessels (such as air tanks), jackets of jacketed vessels, or shells of heat exchangers

4. SHELL: Material T.S. Nominal Thickness 390 In. Corrosion Allowance \_\_\_\_\_ In. Diam. 40 Ft. In. Length 79 Ft. In.  
(Kind and Spec. No.) (Fig. or P.B. & Spec. Min. T.S.)  
5. SEAMS: Long DBL Butt weld S.R. No X.R. Complete Sectioned No Efficiency 90 %  
(Welded, DBL, Single, Lap, Butt) (Yes or No) (Spot or Complete) (Yes or No)  
Girth DBL Butt weld S.R. No X.R. Complete Sectioned No No. of Courses 1  
6. HEADS: (a) Material T.S. (b) Material \_\_\_\_\_ T.S. \_\_\_\_\_  
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)  
(a) Top, bottom, ends 13/32" Ellip. 2:1 Ratio Concave  
(b) Channel \_\_\_\_\_  
(c) Floating \_\_\_\_\_  
If removable, bolts used (a) \_\_\_\_\_ (b) \_\_\_\_\_  
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)  
7. STAYBOLTS: (Material) \_\_\_\_\_ If hollow Attachment \_\_\_\_\_ Pitch X Diam. \_\_\_\_\_ (Nominal)  
(Sire of Hole) (Threaded, Welded) (Horia.) (Vert.)  
8. JACKET CLOSURE: \_\_\_\_\_  
(Describe as open & weld, bar, etc. If bar give dimensions, if bolted, describe or sketch)  
9. Constructed for (Int.) pressure of \_\_\_\_\_ psi. Max. Temp. +100 °F. Subzero -320 °F. Hydrostatic Test 395 psi.

If riveted describe seams fully on reverse side of form

Items 10 and 11 to be completed for tube sections

10. TUBE SHEETS: Stationary. Material \_\_\_\_\_ Diam. \_\_\_\_\_ In. Thickness \_\_\_\_\_ In. Attachment \_\_\_\_\_  
(Kind & Spec. No.) (Subject to Pressure) (Welded, Bolted)  
Floating. Material \_\_\_\_\_ Diam. \_\_\_\_\_ In. Thickness \_\_\_\_\_ In. Attachment \_\_\_\_\_  
(Kind & Spec. No.)  
11. TUBES: Material \_\_\_\_\_ O.D. \_\_\_\_\_ In. Thickness \_\_\_\_\_ Inches or Gage. Number \_\_\_\_\_ Type \_\_\_\_\_  
(Kind & Spec. No.) (Straight or U)

Items 12-15 incl. to be completed for inner chambers of jacketed vessels, or channels of heat exchangers.

12. SHELL: Material 304 SS SA-240 T.S. 75,000 Nominal Thickness 390 In. Corrosion Allowance \_\_\_\_\_ In. Diam. 40 Ft. In. Length 79 Ft. In.  
(Kind and Spec. No.) (Fig. or P.B. & Spec. Min. T.S.)  
13. SEAMS: Long DBL Butt weld S.R. No X.R. Complete Sectioned No Efficiency 90 %  
(Welded, DBL, Single, Lap, Butt) (Yes or No) (Spot or Complete's) (Yes or No)  
Girth DBL Butt weld S.R. No X.R. Complete Sectioned No No. of courses 1  
14. HEADS: (a) Material 304 SS SA-240 T.S. 75,000 (b) Material \_\_\_\_\_ T.S. \_\_\_\_\_ (c) Material \_\_\_\_\_ T.S. \_\_\_\_\_  
Location Thickness Crown Radius Knuckle Radius Elliptical Ratio Conical Apex angle Hemispherical Radius Flat Diameter Side to Pressure (Convex or Concave)  
(a) Top, bottom, ends 13/32" Ellip. 2:1 Ratio Concave  
(b) Channel \_\_\_\_\_  
(c) Floating \_\_\_\_\_  
If removable, bolts used (a) \_\_\_\_\_ (b) \_\_\_\_\_  
(Material, Spec. No., T.S., Size, Number) (Describe or Attach Sketch)  
15. Constructed for (Int.) pressure of 245 w/ psi. Max. Temp. +100 °F. Subzero -320 °F. Hydrostatic Test 395 psi.

If riveted describe seams fully on reverse side of form

Items below to be completed for all vessels where applicable.

16. SAFETY VALVE OUTLETS: Number \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_  
17. NOZZLES:  
Purpose (Inlet, Outlet, Drain) Number Diam. or Size Type Material Thickness Reinforcement Material How Attached  
3 3/4" SA-240 Rod Drilled .385 I.D. Welded  
3 1-1/2" SA-240 1.135 I.D. "  
1 1-1/8" SA-240 .885 I.D. "  
18. INSPECTION Manholes, No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_  
OPENINGS: Handholes, No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_  
Threaded, No. \_\_\_\_\_ Size \_\_\_\_\_ Location \_\_\_\_\_  
19. SUPPORTS: Skirt (Yes or No) \_\_\_\_\_ Lugs (Number) \_\_\_\_\_ Legs 3 Location \_\_\_\_\_ Other 3 BRACE Attached shell - brace  
(Describe) (How)  
20. REMARKS: 48" I.D. Liquid Oxygen Storage Vessel Rods rods welded to top head

We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this unfired pressure vessel conform to the ASME Code for Unfired Pressure Vessels.

Date APR 19 1961 Signed Ryan Industries, Inc. By J. Magyar  
(Manufacturer)  
Certificate of Authorization Expires #956 12-31-61

**CERTIFICATE OF SHOP INSPECTION**

Inspection Agency's Serial No. HSB-1057  
VESSEL MADE BY Ryan Industries, Inc. at Cleveland, Ohio

I, the undersigned, holding a Certificate of Competency as an Inspector of Boilers and Unfired Pressure Vessels in  
THE STATE OF Natl. Bd. and employed by Hartford Steam Boiler Inspection & Insurance Co. of Hartford Conn.  
inspected internally and externally, the vessel described in this report on \_\_\_\_\_ 19\_\_\_\_\_, and certify  
that the statements made in this report are correct corresponding with mill test reports of materials furnished by the builders, and measurements  
made of the vessel and that this vessel is constructed in accordance with the ASME Code for Unfired Pressure vessels.

Date APR 19 1961 \_\_\_\_\_ 19\_\_\_\_\_  
B. Boghyan Commissions Ohio #1517  
Inspector's Signature Penna #WC 1033  
N.B. #4902  
State or Nat'l Bd. # Number

**CERTIFICATE OF FIELD ASSEMBLY INSPECTION**

I, the undersigned, holding a Certificate of Competency as an Inspector of Boilers and Unfired Pressure Vessels in  
THE STATE OF \_\_\_\_\_ and employed by \_\_\_\_\_ of \_\_\_\_\_  
have compared the statements in this manufacturers' data report with the completed vessel, and certify that parts referred to as data items  
\_\_\_\_\_ were completed in the field in accordance with the requirements  
of the ASME Code for Unfired Pressure Vessels. The completed vessel was inspected and subjected to a hydrostatic test of \_\_\_\_\_ psi.

Date \_\_\_\_\_ 19\_\_\_\_\_  
Inspector's Signature Commissions \_\_\_\_\_  
State or Nat'l Bd. # Number